



Salvatore D. Ianiero

16 Chestnut Street, Suite 220
Foxboro, MA 02035
Tel (401) 533-0728
Fax (774) 215-5423

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RECEIVED
JAN 31 2014

CONNECTICUT
SITING COUNCIL

Re: **Notice of Exempt Modification - Emergency Backup Generator**
FA#: 10070938/ 49 South Road, Bolton, CT 06043/ Project Code: 2051691687

Dear Ms. Bachman:

American Telephone and Telegraph Company ("AT&T") currently maintains a wireless telecommunications facility at the above referenced address. AT&T's facility consists of antennas at the 190' mark of the existing 190' tower and an existing AT&T equipment area. The tower and AT&T's area are located within an existing lease area. The shelter houses AT&T's equipment and space for a back-up generator. AT&T does not currently maintain a generator at this cell site.

In an effort to further enhance multiple tenants' network reliability, AT&T intends to modify its facility by installing a new diesel generator outside in a designated 4'x8' ground space. The generator incorporates a built-in fuel tank as part of the unit. The diesel fuel tanks are double walled for added safety and will be filled by a licensed fuel filling company. The proposed modification will remain within the existing fenced compound within the limits of the existing lease area. The new generator and tank will be surrounded by a security fence and gate. (See Facility Compound Plan attached).

Please accept this letter as notification pursuant to R.C.S.A Section 16-50j-73, for construction that constitutes modification pursuant to R.C.S.A Section 16-50j-72(b)(2). In accordance with R.C.S.A Section 16-50j-73, a copy of this submission is being sent to the Town of Bolton. A copy of this submission is also being sent to Leonard W. & Cheryl P. Giglio, the property owners on which the tower is located.

ATCs' Proposed Wireless Modifications Constitutes An "Exempt Modification"

The proposed modification to the above mentioned Facility constitutes an exempt modification of an existing facility provided for in R.C.S.A Section 16-50j-72(b)(2) and Council regulations promulgated pursuant thereto.

- 1) The proposed modification will not result in an increase in the height of the existing tower.
- 2) The generator and attached fuel tank will remain entirely within the limits of the leased area. The modifications therefor, will not require the extension of the boundary.
- 3) The proposed modification does not increase the noise levels at the boundary by six(6) decibels or more under normal conditions. Proposed modification is only used during emergency power failure.
- 4) The installation of a new generator and attached fuel tank will not change, in any way, radio frequency (RF) emissions at the facility.
- 5) The facility has received all municipal zoning approvals and building permits. (Regs., Conn. State Agencies Section 16-50j-72))

For all the foregoing reasons, American Telephone and Telegraph Company respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitutes an exempt modification under R.C.S.A Section 16-50j-72(b)(2)

Respectfully submitted,




Sal Ianiero 401-533-0728

On behalf of American Tower Corporation
c/o Tower Resource Management, Inc.
16 Chestnut Street, Suite 220
Foxboro, MA 02035

cc: **Town of Bolton, CT**
Leonard W. & Cheryl P. Giglio





Exhibit 1

Site Plan



NOTE: A SITE VISIT/SURVEY WAS NOT CONDUCTED BY ADVANCED ENGINEERING GROUP, P.C. SITE INFORMATION AND PLANS ARE BASED UPON INFORMATION PROVIDED BY CLIENT.



| | | | | | | | | | |
|---|--|--|--|---|--|--|--|--|--|
|  ADVANCED ENGINEERING GROUP, P.C. Civil Engineering - Site Development Surveying - Topographical 590 NORTH BROADWAY SUITE 400 FARMINGTON, CT 06031 TEL: 401-353-4543 FAX: 401-353-8554 | |  TRM Consulting Network, Inc. 15 HARTFORD AVENUE, SUITE 202 HARTFORD, CT 06105 WWW.TRM-ADV.COM | |  at&t | | SITE NUMBER: 10070938 SITE NAME: BOLTON | | SITE ADDRESS: 48 SOUTH ROAD BOLTON, CT 06033 | |
| STAMP HERE: JWS 3/26/01 BY: JWS CHECKED BY: SMA DATE DRAWN: 12-27-03 JOB NO.: 10070938 | |  | | SHEET NUMBER: A-1 | | REV: 1 | | COMPOUND PLAN | |